

WA105 

Status and plans


Laura Molina Bueno
&
Laura Manenti

ETH Zürich



Status

- **Cryogenics:** Purge of main pipes (those external to the cryostat) performed before CERN Christmas closure.
- **Manhole successfully closed** (19/12/2016), along with all other flanges in December.
- **Purge in open loop:** On December 20th we started flushing the cryostat with GAr. We started the purge through the pump tower to evacuate the pump tower volume (10 volumes of the pump tower needed to be flushed).



First step of purge in open loop:

Flush GAr through the pump line into the vessel, in this way we remove air and impurities trapped inside. Then the gas exits the main cryostat through the 2 cryogenics valves welded onto the pump tower (HV4160 and HV4161).

Status

- **Cryogenics:** Purge of main pipes (those external to the cryostat) performed before CERN Christmas closure.
- **Manhole successfully closed** (19/12/2016), along with all other flanges in December.
- **Purge in open loop:** On December 20th we started flushing the cryostat with GAr. We started the purge through the pump tower to evacuate the pump tower volume (10 volumes of the pump tower needed to be flushed). **Leaks coming from the pump tower were found**. Causes for these leaks were identified on December 21st and early in January 2017:
 - a. A large leak at the level of the **CF250 flange** gasket. When we opened we found there was no incision on the copper gasket. We found the gasket was at the same height of the rotatable flange. We will solve the issue by putting a spacer underneath.
 - b. The gasket in the **CF-400 flange** was not properly fixed because the flange was deformed (not perfectly flat and round). This has been solved by carefully screwing and positioning the gasket.

Problem reported on ELOG 66


Copper gasket slightly marked on two ends while there was no mark on the other two ends.

In addition, was difficult to keep the gasket in the correct position.

This might be due to either the deformation of the gasket itself or the CF400 flange at the top cap.


We pressed an aluminium bar tightly at one end of the flange to keep the bar parallel to the flange, on the other end of the flange there was clearly a gap ~ 3-5 mm between the bar and the flange.

This was found everywhere on the flange.



Status


- **Major leak from pump tower to main volume:** there are two manual valves which connect the pump tower to the cryostat. We realized that even when both were closed, there was gas going from the pump tower to the cryostat. By inspecting with an endoscope, we found that **one of the bellows was broken**. It might have been damaged during transport. Last week, **we dismantled the pump tower and sent it to the CERN workshop for repairing and reinforcing. This is now fixed**: the pump tower has already been mounted on Wednesday (17/01/2016), whereas the pump has been reinstalled now. We are now able to re-start the purge in open loop!




broken bellow



Esegue le
SALDATUR



Pressure vs time of tank



Status


Second step of purge in open loop:

Instead of using the pump tower line, we use the lines drawn in blue in the picture. There are total 4 lines each with 3 openings of 12 mm diameter to perform the purge of the cryostat at 10g/s (or higher/lower).

These lines are below the PMTs.

The two lines on the sides are facing sideways and the two lines in the middle are facing downwards.

This means no detector component is directly exposed to the gas while purging.



Status

- **DAQ system (Dario and Slavic will present a summary today):**
 - Successfully installed on December 2nd.
 - *Noise*: additional measurements (which add to the ones performed during summer/fall 2016) with the DAQ performed before Christmas and last week:
 - i. ELOG entry summarizing measurements performed 18/10/2016-20/10/2016
<http://lbnodemo.ethz.ch:2500/3x1x1/48>
 - ii. ELOG entry summarizing measurements performed 14/12/2016-14/12/2016:
<http://lbnodemo.ethz.ch:2500/3x1x1/71>
 - iii. ELOG entry summarizing all the runs taken during 12/01/2017 and 13/01/2017:
<http://lbnodemo.ethz.ch:2500/3x1x1/72>
 - *Problematic channels*: We found some problematic channels and after further investigation we realised that there were some connectors badly soldered on the warm flange on SGFT3. After repairing them, the percentage of problematic channels went down from 3% to 1%.
 - *First data* is already in `EOS:/eos/experiment/wa105/data/311/calibrations`

Plans

Month	Mon	Tue	Wed	Thu	Fri	Sat	Sun
			Pump tower installed	Pump installed			
Jan	16	17	18	19	20	21	22
	Purge in open loop						
Jan	23	24	25	26	27	28	29
	Purge in closed loop						
Jan-Feb	30	31	1	2	3	4	5
	Start cool down						
Feb	6	7	8	9	10	11	12
Feb	13	14	15	16	17	18	19
Feb	20	21	22	23	24	25	26
Feb-Mar	27	28	1	2	3	4	5

Plans for next weeks

- Ongoing general high voltage tests:

WA105 - External Display									
NAME	DESCRIPTION	VALUE	UNIT	NAME	STA.	VMON (V)	IMON (uA)	NAME	STAT.
PE0001	$\Delta P(\text{IS-Atm})$ - Input	1.487	mBar	LEM01 UP	ON	99.01	0.000	LEM01 DW	ON
PE0002	$P(\text{IS})$ - Structure	975.3	mBar	LEM02 UP	ON	99.72	0.000	LEM02 DW	ON
PE0003	$\Delta P(\text{IS-Atm})$ - Top junction	1.674	mBar	LEM03 UP	ON	99.51	0.000	LEM03 DW	ON
PE0004	$P(\text{IS})$ - Top Cap	976.6	mBar	LEM04 UP	ON	99.17	0.000	LEM04 DW	ON
PE0005	$\Delta P(\text{IS-Atm})$ - Top Cap	1.690	mBar	LEM05 UP	ON	98.62	0.000	LEM05 DW	ON
PE0006	$P(\text{Tank})$ - Top Cap	1006.0	mBar	LEM06 UP	ON	99.75	0.000	LEM06 DW	ON
PE0007	$\Delta P(\text{Tank-IS})$ - Top Cap	24.553	mBar	LEM07 UP	ON	99.28	0.000	LEM07 DW	ON
PE0008	$\Delta P(\text{Tank-Atm})$ - Top Cap	23.035	mBar	LEM08 UP	ON	99.19	0.004	LEM08 DW	ON
PE0009	$\Delta P(\text{SGFT01-Atm})$	15.1	mBar	LEM09 UP	OFF	0.00	0.000	LEM09 DW	OFF
PE0010	$\Delta P(\text{SGFT02-Atm})$	21.6	mBar	LEM10 UP	OFF	0.00	0.000	LEM10 DW	OFF
PE0011	$\Delta P(\text{SGFT03-Atm})$	12.8	mBar	LEM11 UP	OFF	0.00	0.000	LEM11 DW	OFF
PE0012	$\Delta P(\text{SGFT04-Atm})$	24.7	mBar	LEM12 UP	OFF	0.00	0.000	LEM12 DW	OFF
PE0013	$P(\text{SCFT01})$	963.9	mBar	FFS1	OFF	4.00	0.000	FFS2	OFF
PE0015	$P(\text{SCFT03})$	1005.3	mBar	GRID1	ON	100.00	0.000	GRID2	OFF
PE0016	$P(\text{Atm})$	974.7	mBar	HV Heinz.	OFF	5.34	7.94		
ALARMS & CONTROL									
SC READY CRYO READY UPS DEFAULT ANS LED STATUS PMT 01 PMT 02 PMT 03 PMT 04 PMT 05 Heinzinger									

- Test and monitor Heinzinger Power supply display ongoing.
- Once, we move to close loop:
 - Test the LEMs and monitor the leakage current.
 - Calibrate level meters.
- PMT and CRT trigger needs to be finalised.
- Display DB almost ready.

A new webpage is accessible inside CERN (created by Yann): <http://wa105-extdisp:3800/index.html> (no login) to have a quick view of HV, pressure, LEDs...